



CITY OF KENT

Division of Water

2015 DRINKING WATER CONSUMER CONFIDENCE REPORT

The City of Kent remains committed to providing our residents with a safe and reliable supply of the highest-quality drinking water. We continue to test our water using sophisticated equipment and advanced procedures. In year 2015 we had an unconditional license (OH6701812) to operate our water system. The City of Kent water meets all state and federal standards for both appearance and safety. As a matter of record, all City of Kent Water Plant Operators possess Ohio EPA Operator Certification. In addition, three personnel are Ohio EPA certified to do bacteria testing. This annual "Consumer Confidence Report," required by the Safe Drinking Water Act (SDWA), tells you where your water comes from, what our tests show about it, as well as other things you should know about drinking water.

We are proud to report that the water provided by the City of Kent continues to “meet or exceed” all established water-quality standards.

We encourage public interest and participation in our community's decisions affecting your drinking water. Regular City Council Meetings are held on the 1st and 3rd Wednesday of each month, at 320 South Depeyster Street, in the Kent Council Chambers at 7:30 p.m. We invite and welcome the public at these meetings.

Overview

In the year 2015, we had three major projects at the Kent Water Treatment Plant. Two of them were planned and one was an unexpected emergency. Our first big project was lead abatement and a paint system applied to the Fairchild water tank. The

project, done on time and on budget, included several improvements. The overflow was re-directed to “air” as opposed to the storm sewer as the EPA mandated. New wiring, for telemetry, lights, heaters, and outlets was updated and a new security gate was installed.

The second huge upgrade was controlling all five booster pumps with telemetry and new variable frequency drives, provided, designed and supplied by Rovisys Company. Their work, thus far has exceeded expectations. It also gives us maintenance options we did not have in the past by being able to isolate one booster station to work on the other.

Unexpected, was the clogging of the suction Screen of #10 production well. This necessitated an earlier than anticipated cleaning and a change in our well maintenance schedule. We will be cleaning wells on a four year rotation rather than a five year schedule.

Water Source Information

The City of Kent is supplied by groundwater, which is pumped from several wells located very close to the water plant. Our well field is known as the "Breakneck Creek Well field", which taps into the "Buried Valley Aquifer". The exception is Well No. 13. It is considered a rock well, as it taps into a formation of water bearing sandstone. The high purity well water is first delivered to your water plant where it is treated. The treatment includes softening, filtration, stabilization (to prevent it from being corrosive), disinfection, and fluoridation, for your benefit.

A Source-Water Assessment has been performed for our area to provide baseline data about the quality of water before it is treated and distributed to customers. This Source-Water Assessment was completed as a part of a wellhead delineation

area and pollution source inventory in our Wellhead Protection Plan. This is important because it identifies the origins of contaminants within our area and indicates the susceptibility of our water system to such contaminants. The aquifers that supply drinking water to the City of Kent's Breakneck Creek Well field, and Well 13 have a high susceptibility to contamination, due to the sensitivity of the aquifer in which the drinking water wells are located, and the existence of

several potential contaminant sources within the protection zone. This does not mean that either well field will become contaminated, only that conditions are such that ground water could be impacted by potential contaminant sources. Future contamination may be avoided by implementing protective measures. The City of Kent has taken some proactive steps to monitor and protect this precious resource. More information is available by contacting the Ohio E.P.A., Northeast District Office, 2110 E. Aurora Road, Twinsburg, Ohio 44087-1969.

Water Quality Data

The following table lists the only drinking water contaminants that were found during or prior to the 2015 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. It is important to understand that the treatment process our water undergoes, makes it far safer than most water supplies anywhere in the world. Unless otherwise noted, the data presented in this table is from testing performed January 1st through December 31st, 2015. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

How to Read This Table

It's easy! Our water is tested to assure that it is safe and healthy. The column marked "Level Found" shows the highest test results during the year. A "Source of Contaminant" shows where this substance usually originates. Footnotes explain important details. Columns headed MCL, AL and MCLG refer to:

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology. **Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which, there is no known or expected risk to health. MCLG's allow for a margin of safety. **Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirement that a water system must follow

The data presented in this report is from the most recent testing done in accordance with regulations.

Key To Table

AL = Action Level MCL = Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

MFL = million fibers per liter

pci/l = picocuries per liter (a measure of radioactivity)

ppm = parts per million, or milligrams per liter (mg/l)

ppb = parts per billion, or micrograms per liter (µg/l)

BDL = below detectable limits

We have performed testing for many different potential contaminants, but only the listed substances were found. Of those substances that were found, all are below the MCL limit. We also collected 384 routine samples for bacteriological examination throughout the city during the year of 2015. We are pleased to report that each of these samples were negative (no bacteria present).

Contaminant	Sample Year	Unit	MCL	MCLG	Level Found	Range of Detections	Sources of Contaminants	Violation
Inorganic Contaminants Fluoride	2015	ppm	4	4	0.93	0.89 -1.02	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	NO
Lead	2014	ppb	AL = 15	0	<5.0	1@ 8.6 ppb	Corrosion of household plumbing systems.	NO
							Zero out of 30 samples was found to have lead levels in excess of the lead action level of 15 ppb.	
Copper	2014	ppb	AL = 1300	0	<50	1@ 101ppb	Corrosion of household plumbing systems.	NO
							Zero out of 30 samples was found to have copper levels in excess of the copper action level of 1300 ppb.	
Nitrate	2015	ppm	10	10	<0.10	NA	Runoff from fertilizer use; Erosion of natural deposits.	NO
Volatile Organic Contaminants Total Trihalomethanes TTHMs	2015	ppb	80	0	67.1	37.1-67.1	By-product of drinking water chlorination	NO
Haloacetic Acids HAA5	2015	ppb	60	0	10.1	6.7-10.1	By-product of drinking water chlorination	NO
Residual Disinfectants Total Chlorine (ppm)	2015	ppm	4	4	1.20	0.35-1.89	Water additive to control microbes	NO

Disinfection By Products

Disinfection byproducts are the results of providing continuous disinfection of your drinking water and form when disinfectants combine with organic matter naturally occurring in the source water. Disinfection byproducts are grouped into two categories, Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5). USEPA sets standards for controlling the levels of disinfectants and disinfectant byproducts in drinking water, including both TTHMs and HAA5s.

TTHM's Health Effects

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.

Additional Water Quality Monitoring

Our water system participates in the Ambient Ground Water Monitoring Program, which is administered by the Ohio E.P.A.'s Division of Drinking and Ground Waters. As a result, our ground water source is subjected to additional extensive analysis every six to eighteen months. While this analysis is not used to fulfill our monitoring requirements, it does provide us with additional assurance of the quality of our source water.

Additional Information That May Be Of Interest:

Chemical Analysis (Annual Average 2015)

Raw Water (untreated) Tap Water (treated)

Alkalinity	220 mg/l	48 mg/l
Hardness	322 mg/l	96mg/l

Non-Carbonate	102mg/l	48mg/l
Calcium (as Ca)	97 mg/l	18 mg/l
Magnesium (Mg)	13mg/l	12 mg/l
Fluoride	0.12mg/l	0.93mg/l
P.H.	7.41	9.29

Sources of Contamination in Drinking Water and Additional Health Information

To ensure that tap water is safe to drink, the EPA prescribes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Source Water Protection

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Lead in Drinking Water

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Kent is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting several hours, you can minimize the potential for lead exposure by flushing your tap from 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about the lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”

Special Information Available

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer who are undergoing chemotherapy, persons who have undergone

organ transplants, people with HIV/AIDS or other immune disorders, some elderly people, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate ways to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). In order to insure that tap water is safe to drink, EPA prescribes regulations which limit certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Additional Questions?

In addition to the testing that we are required to perform, our water system voluntarily tests for hundreds of additional substances and microscopic organisms to make certain our water is safe and of high quality. For more information, call the City of Kent at (330) 676-6333. We are here to serve **YOU!** Please feel free to call us with any questions that you may have.